Manatee County Project Management Inspections Services Division
Charge Sheet / Testing / Inspections Report

Testing Date 4-22-14 **Scheduled By** _____

Manatee County Rep Engineer Rep Date

Project Summary

Project Name / # First Baptist Church of Gillette FSP-12-02
Project Location 3301 Mocassin Wallow Road, Palmetto, FL.
Engineer of Record Allison / Gause **Phone #** 708-5400
Contractor AROK Bobby Merrill **Phone #** 377-2520

Service Type

Portable / Reclaimed Water
Tap Cut-In Tie-In
Pressure Test Other Continuity Test

Wastewater
FM Air Testing Manhole(s) Lift Station
Lamping/TVing Corebore/Lining
Mandrel Testing Other _____

Description of Work

		Start Time	End Time
Inspector 1	John Peterson	_____ AM / PM	_____ AM / PM
Inspector 2		_____ AM / PM	_____ AM / PM

Comments / Punch List

Continuity test (Potable) - Tested from 6" tapping saddle/GV to Back Flow Preventer & Meter (43LF)

Continuity test Force Main - From Wet well to Lift Station 1468LF

Test Pass - both FM + Potable

Test Equipment: Dynatel Model 2210 Cable Locator

Continuity test

Type of Test	Hours
Initial Test (Pass) / Fail	
Re-Test #1 Pass / Fail	
Re-Test #2 Pass / Fail	
Re-Test #3 Pass / Fail	

Type of Test	Hours
Initial Test Pass / Fail	
Re-Test #1 Pass / Fail	
Re-Test #2 Pass / Fail	
Re-Test #3 Pass / Fail	

Type of Test	Hours
Initial Test Pass / Fail	
Re-Test #1 Pass / Fail	
Re-Test #2 Pass / Fail	
Re-Test #3 Pass / Fail	

Manatee County Inspector (Print Name) John Peterson (Signature) John Peterson
Engineer of Record (Print Name) BRAD THARP (Signature) [illegible]
Contractor (Print Name) Joe Rosko (Signature) Joe Rosko

MANATEE COUNTY REPRESENTATIVE MUST BE PRESENT AT ALL TESTING
Public Works Department – Infrastructure Inspections Division (941) 708-7450 X7346 / (941) 708-7548 (Fax)
White Copy – Inspector Yellow Copy – Engineer of Record Pink Copy - Contractor

Rev 06/13