



Utilities
Wastewater Compliance
3525 Lena Road
Bradenton, FL 34211
Phone: (941) 792-8811, ext. 5180
www.mymanatee.org/utilities

Local Limits

No person shall discharge wastewater containing pollutants in excess of the following instantaneous maximum allowable discharge limits:

2.51 mg/L Arsenic
7290 mg/L cBOD5
287 mg/L Chloride
0.73 mg/L Cadmium
9.90 mg/L Chromium
28.48 mg/L Copper
4.70 mg/L Cyanide
1.87 mg/L Lead
0.38 mg/L Mercury
1.26 mg/L Molybdenum
11.08 mg/L Nickel
2.11 mg/L Selenium
16.06 mg/L Silver
1830 mg/L Total Suspended Solids
4.78 mg/L Zinc

The above limits apply at the point where the wastewater is discharged to Manatee County's sanitary sewer collection system. All concentrations for metallic substances are for "total" metals unless indicated otherwise. The Director may impose limitations in addition to, or in place of, the concentration-based limitations above.